


PRODUCT MANUAL.

600 S 24



DELTAELEKTRONIKA

DC POWER SUPPLIES

Safety Instructions

Caution

The following safety precautions must be observed during all phases of operation, service and repair of this equipment. Failure to comply with the safety precautions or warnings in this document violates safety standards of design, manufacture and intended use of this equipment and may impair the built-in protections within. Delta Elektronika shall not be liable for user's failure to comply with these requirements.

Installation Category

The Delta Elektronika power supplies have been evaluated to installation category II.(Over voltage category II)

Grounding of Mains Input

This product is a safety Class 1 instrument. To minimize shock hazard, the instrument chassis must be connected to the AC Power Supply mains through a three or four conductor power cable for resp. a single or three phase unit, with the ground wire firmly connected to an electrical ground (safety ground) at the power outlet.

For instruments designed to be hard-wired to supply mains, the protective earth terminal must be connected to the safety electrical ground before another connection is made. Any interruption of the protective ground conductor, or disconnection of the protective earth terminal will cause a potential shock hazard that might cause personal injury.

Grounding of Power Output

If the output of a unit is specified to deliver max 60Vdc, and either the negative or positive power output is grounded, the voltage on the following connections can be considered safe:

- power outputs and sense connections
- programming/monitor/status-signals, Interlock, Master/Slave-connections, ACF/DCF-relay
- all Delta Elektronika interfaces.

Warning:

When the positive power output can exceed 60Vdc in respect to the negative output, additional external measures must be taken to ensure safety isolation of the following:

- power outputs and sense connections.

Warning:

When the negative power output of the unit can exceed 60Vdc / 42.4Vpk in respect to ground, additional external measures must be taken to ensure safety isolation of the following:

- power outputs and sense connections
- programming/monitor/status-signals, Interlock, Master/Slave-connections, ACF/DCF-relay
- interfaces with operational isolation
- non-isolated interfaces.

Caution 1: If a low voltage unit has both power outputs floating, or if the output is in series with an external high AC or DC voltage, the negative power output can exceed the safe value in respect to ground as specified in the above warning!

Caution 2: Although a high voltage unit is set to a safe voltage below 60V, for safety it must always be considered as high voltage unit! Wrong operation, a programming error or an external defect can result in an unsafe high output voltage.

Caution 3: When programming a high voltage unit directly via a PC or via a network connection, either ground the negative power output or use a safety isolated interface!

For more information and schematics regards Grounding and Safety, see the special application note "Safe operation of a power supply" on the Delta Elektronika website.

Fuses

Fuses must be changed by authorized Delta Elektronika service personnel only, for continued protection against risk of fire.

Input Ratings

Do not use an AC Supply which exceeds the input voltage and frequency rating of this instrument. The input voltage and frequency rating of the Delta Elektronika power supply series are stated in the accompanying datasheet.

Live Circuits

Operating personnel must not remove the instrument cover. No internal adjustment or component replacement is allowed by non Delta Elektronika qualified personnel. Never replace components with the power cable connected. To avoid injuries, always disconnect power, discharge circuits and remove external voltage sources before touching components.

Parts Substitutions & Modifications

Parts substitutions and modifications are allowed by authorized Delta Elektronika service personnel only. For repairs or modifications the unit must be returned to a Delta Elektronika service facility.

Removal of (safety) covers

Safety cover(s) are used to cover potentially hazardous voltages.

Observe the following when removing safety cover(s):

- Switch off the unit.
- Disconnect the unit from the mains supply.
- Wait for 3 minutes to allow internal capacitors to discharge.
- Unscrew the screws and remove the cover(s).
- Always place the cover(s) back before connecting the unit to the mains supply again.

Environmental Conditions

The Delta Elektronika power supplies safety approval applies to the following operating conditions:

Indoor use

Ambient temperature : -20 to 50 °C

Maximum relative humidity : 95%, non condensing, up to 40 °C

: 75%, non condensing, up to 50 °C

Altitude: up to 2000 m

Pollution degree 2



Caution risk of electrical Shock



Instruction manual symbol. The instrument will be marked with this symbol when it is necessary for the user to refer to the instruction manual



Protective ground conductor terminal



Off (supply)



On (Supply)

WEEE


(Waste Electrical & Electronic Equipment)

Correct Disposal of this Product

Applicable in the European Union.



This marking shown on the product, its packing or its literature indicates that it should not be disposed with other wastes at the end of its working life, but should be collected separately to recycle it responsibly to promote the sustainable reuse of material resources.




			Title: 1200S24	
			1200S48 600S24	
			Date: OKT 90	
Modifications	Date	App.	DELTA ELEKTRONIKA BV	

Warning


Before opening the enclosure disconnect the unit from the line voltage and wait three minutes to give the electrolytic capacitors time to discharge.

Also be careful with the low voltage high current output because it can cause harm when a ring or wrist watch, attached to a person, shorts the output terminals. Also a high current can vaporize metallic objects such as screwdrivers and the molten metal can be sprayed on people.


Installation and operation



Input voltage selector block




The power supply has a wide input voltage range. With the jumper in the 230 V position it can be used at any line voltage between 200 and 264 V AC 48/62 Hz. For DC input voltage contact factory. Put fuse 6.3 A in fuse holder.



With the two jumpers in the 115 V position it can be used at any line voltage between 100 and 132 V AC 48/62 Hz. A DC input cannot be used with the jumpers in this position since the input circuit is connected as a voltage doubler. Put fuse 12.5 A in fuse holder.

Sense block




For normal operation S+ has to be connected to + and S- to -.


Recommended wire sizes

Model	INPUT		OUTPUT	
	230 V AC	115 V AC		Voltage drop
600 S 24	2.5 mm ²	2.5 mm ²	6 mm ²	75 mV/m at 25 A

Inrush current



The inrush current limiter limits the inrush current to about 40 A during 5 milliseconds. At turn on the electrolytic capacitors charge through a PTC series resistor of about 40 Ohms. When they are charged sufficiently the series resistor is shorted by a heavy relay contact and the power supply starts operating. In case of a relay failure the PTC becomes high ohmic and limits the current to a safe value.




Inrush current 600S24
Vertical 20 A / div.

Input choke (passive power factor correction)

A switched mode power supply with a bridge rectifier and an electrolytic capacitor at the input takes current only in the peaks of the sine waves. These narrow current peaks can cause distortion in the line voltage. To improve the line current the 600S24 has a large low frequency choke with an air gap at the input. The crest factor (I_{peak}/I_{rms}) is 1.8. The harmonic current meets EN 61000-3-2.

Vertical mounting



For convection cooling the ideal way of mounting is vertically. For the best internal heat distribution it is recommended to keep the input block at the upper side.

The power supply is so constructed that the heat generated in the semiconductors and transformer flows through a thick aluminium profile to both covers which act as heat sinks. So it is important that the air can flow freely vertically along both sides. This design with natural convection cooling was chosen to avoid the use of a blower which has disadvantages like noise, dust filters, wear and tear. For vertical mounting two types of brackets are available H88 and H114.

Horizontal mounting

Horizontal mounting is also possible.

When used in a 19" rack keep sufficient space around the unit for cooling. If more power supplies are mounted above each other the use of forced air to cool is recommended.

For 19" rack mounting brackets H88 with a handle are available.


At 600 W output and 89% efficiency the total heat dissipation is $600 \text{ W} / 0.89 - 600 \text{ W} = 75 \text{ watts}$.

Remote sensing




For most applications remote sensing is not necessary. However, if the voltage at the load has to be kept very constant (within millivolts) and the voltage drop across the load leads is large, remote sensing is useful. With remote sensing the voltage is kept constant across the load instead of at the output terminals of the power supply. The maximum sense range per load lead is 3V. However the voltage across the output terminals, which is the sum of the voltage across load plus leads, cannot exceed 30 V. The two load leads have to be kept closely parallel to minimize the inductance. If there is a capacitor at the load it can together with the lead inductance cause oscillations. This can be stopped by an electrolytic capacitor of 12000 μF at the load. Also the sense leads have to be kept close together to minimize pick up of noise.

Parallel operation



To obtain higher current two or more units can be used in parallel. Before connecting them in parallel first adjust each output to the same voltage. However it is more economical to use a 1200S24 instead of two units 600S24.

Redundant parallel operation




Adjust outputs till difference is zero

For redundant operation the 600S has a built in series diode and an undervoltage alarm contact. This contact can be used as normally open or as normally closed.

To get a reasonable current sharing the output voltages of the two or more units have to be adjusted to the same voltage. An easy way is to measure the voltage difference at a low range of a multimeter and adjust this to zero. After careful adjustment the current sharing is usually within 10%.

It is also important that all the load leads to the summing points have the same resistance (same length).


Remote voltage control



Voltage adjustment with an external potentiometer of 10 kOhms is possible if R 120 and R 110 are removed. The potentiometer can be connected as a variable resistor between S+ and + at the sense block. The internal potmeter has to be turned to zero.

This method of voltage control by external potentiometer cannot be used with parallel operation.

Remote programming



Attention: The programming input is not isolated. The zero of the progr. input is connected to minus output. When the small switch near the programming input is put on PROG (program) the output voltage of the power supply can be programmed by an analog voltage of 2 to 5 V, corresponding with 12 to 30 V output.


The programming speed is 100 milliseconds for a change from 12 to 30 V at full load.

The programming range 2-5 V can be calibrated with the 10-turn voltage adjustment potentiometer. To calibrate put 5V at the programming input and turn the voltage adjustment potentiometer until the output voltage is 30 V.

Remote shut down

Remote shut down of the output voltage is possible by 5 V (3-12 V) at the RSD input. The RSD input is low ohmic (500 Ω). The RSD input is isolated from the output by an optocoupler (isolation 1000 V).

Programming Block



Current limit

The current limit is fixed and has a more or less constant power characteristic.

Insulation test

The insulation of 4000 Vrms between input and output cannot be tested at the complete power supply because the input to case insulation is 2500 Vrms and the output has to be shorted and connected to the case during a test with such a high voltage (insulation output to case is 500 V DC).

The separating components like the transformer are tested before mounting.

The creepage distances between input and output circuits at the PCB are more than 8 mm. The optocoupler is specified for 5 kVrms.

The input to case insulation of 2500 rms (1 minute) can be tested if the output is shorted and connected to the case.

If the test is made with AC a current will flow through the Y-capacitors of the input RFI filter. This is no problem for the Y-capacitors (they are specified 4 kVrms 1 min.) but it looks like a leakage current. It is more practical to test with a DC voltage of $1.4 \times 2500 \text{ V} = 3500 \text{ V}$.




Dividing the load in sections, each with its own fuse

In general it is not recommended to use a fuse in the DC output of an electronic regulated power supply. The electronic current limit is very fast compared to fuses and it is sharply defined so there is not enough time and not enough overcurrent to blow a fuse.



This makes it difficult to divide the load in sections each with its own fuse.

Even for very fast fuses the time to blow is still in the order of 50 seconds at twice the nominal current ($2 I_N$). At $4 I_N$ this is already much better and can be in the order of 20 milliseconds.

However compared with the electronic current limit this is still too long and all sections will see a dip in the 24 V. The best results we found with the circuit breakers S 280 Z of ABB. They are the fastest.



In the above situation there is still a considerable voltage dip during 8 ms. This can be improved by one or more large electrolytic capacitors which can supply a high current peak for a fast action of a fuse or a circuit breaker.



600 S 24 with 36 000 μF parallel

A disadvantage of the large electrolytic capacitor can be that the current limit is no longer fast.

The inductance of long leads (several meters) between the power supply and the load can cause very large voltage dips when a fuse is blown. This can be avoided by connecting the electrolytic capacitor close to the load.



P.O. Box 27
4300 AA Zierikzee
The Netherlands

Tel. +31 111 413656
Fax. +31 111 416919
www.deltapowersupplies.com

DELTA ELEKTRONIKA B.V.

EC Declaration of Conformity

We

Delta Elektronika
P.O. BOX 27
4300 AA ZIERIKZEE
The Netherlands

Declare under sole responsibility that the following Power Supply:

600 S 24

Meets the intent of Directives 2004/108/EC for Electromagnetic Compatibility and Directives 2006/95/EC regarding Electrical Safety. (Low Voltage Directive)
Compliance was demonstrated to the following specification as listed in the official Journal of the European Communities:

EN 61000-6-3 Generic Emissions: (residential, light industrial)

EN 55022 Radiated and conducted, Class **B**
EN 61000-3-2 Power Harmonics
EN 61000-3-3 Voltage fluctuation and flicker

EN 61000-6-1 Generic Immunity: (residential, light industrial)

EN 61000-6-2 Generic Immunity: (industrial environment)

EN 61000-4-2 Electrostatic Discharge
EN 61000-4-3 Radiated electromagnetic fields
EN 61000-4-4 Electrical Fast Transients / Bursts
EN 61000-4-5 Surge immunity
EN 61000-4-6 RF common mode, conducted
EN 61000-4-11 Voltage variations and dips

EN 60950 Safety of IT equipment

EN 61010 Safety of electrical equipment for measurement, control and laboratory use


Managing director



DELTAELEKTRONIKA B.V.

Delta Elektronika B.V.
Vissersdijk 4
4301 ND Zierikzee
The Netherlands
Tel. +31 111 413656
Fax. +31 111 416919

www.deltapowersupplies.com



DC POWER SUPPLIES